

Vacuum Switch - XV 600Series

CE



Model Type	Setting Interval	Fix Differential
XV600	- 150 to 1000 m bar	150 ± 50 mbar

Specification

- Pressure Connection - brass
- Thread - 1/4" BSP
- Main Body - Techno Polymer (PET)
- Membrane and Sealing - AISI316 and silicon
- Protection Degree - IP00
- Adjustment - by screw
- Electric Intervention - SPDT 10(2)-250VAC
- Electric Connection - Terminal 6.3 × 0.8
- Admitted Temperature - Max. 125°C
- Burst Pressure - higher than 20 bar
- Thermic Drift - 0.04 bar for 100C with respect to Temperature of + 200C



HTA INSTRUMENTATION (P) LTD.,

An ISO 9001: 2015 Certified Company & NABL Accredited Calibration Laboratory as per ISO/IEC 17025: 2005

Your One Stop for Instrumentation Calibration & Service

73, Ramachandra Agrahara, Near T.R. Mills, Chamarajpet, Bangalore - 560018, INDIA

Phone: 080-26749750, 26759253, 26751379, 26751192, Fax: 080-26740681 E-mail : sales@htaip.com Website : www.htaip.com

